ADDENDUM #3 TO SPEC. 06-262

FIRE STATION EXHAUST REMOVAL SYSTEM UPGRADE

Addendum #3 to Spec. 06-262 for **Fire Station Exhaust Removal System Upgrade**, bids to be opened on Wednesday, September 27, 2006 at 12:00 noon.

GENERAL ITEMS:

- 1. The project will require a payment/performance bond at the time of the bid submittal.
- 2. The completion date for the project shall be 120 working days after the notice of award.
- 3. The project is exempt from sales tax.

MECHANICAL ITEMS:

- 1. All existing exhaust fans, except for the maintenance facility, will be replaced with new fans.
- 2. Silencers will be required for all fans as specified and shown on the plans.
- Refer to mechanical equipment schedules. Note #4 should read: "Magnagrip AND Nederman and other approved equals are acceptable for bid, but the contractor shall be responsible for required changes in design."
- 4. Refer to specification section 233522 under 1.9 bidder Qualifications. Bidders must provide 10 references as prescribed by this section. The references will not be required to be within a 250 mile radius.
- 5. Roof and wall penetrations will be reused whenever possible as noted on the plans.
- 6. Vehicle exhaust tailpipe modifications shall be shown as a separate line item for pricing purposes. See attached revised Proposal Page and Bidding Schedule.
- 7. All exhaust track equipment and ductwork shall be mounted on Unistrut directly anchored the building structure. Anchors penetrating only drywall or plaster/lath shall not be acceptable. Garage door support members shall not be used for structural support. Refer to spec section 230513 1.7 Cutting and Patching for cutting and patching requirements.

Specification 06-262 Addendum No. 3 Page 2

ELECTRICAL ITEMS:

- 1. Electrical Contractor to conceal conduit whenever possible. When wiremold is required, utilize wiremold 700 series painted to match ceiling or wall in hallways and living areas. Exposed conduit is acceptable in the Apparatus bays.
- 2. All low voltage control wiring between apparatus bay exhaust fan and control panel to be in 3/4" conduit.
- 3. Exhaust fan EF-1's motor starter should be 30amp in lieu of 60amp in Fire Stations #3, 5, 6, 9, 10 & 14.
- 4. See attached wiring diagram for the exhaust fan and the control panel for additional electrical information. See attached sketch sheet SD-E002.
- 5. See attached typical electrical floor plan for wiring and circuit changes. The dedicated circuit for the control panel was not required (see attached wiring diagram). See attached sketch sheet SD-E001.

END OF ADDENDUM

All other terms and conditions to remain unchanged.

Dated this 18th day of September, 2006.

Purchasing Department

Tom Kopplin
Assistant Purchasing Agent

Company Name	
--------------	--

PROPOSAL SPECIFICATION NO. 06-262 Revised

BID OPENING TIME: 12:00 NOON DATE: Wednesday, October 27, 2006

The undersigned bidder, having full knowledge of the requirements of the City of Lincoln for the below listed items and the contract documents (which include Notice to Bidders, Instructions to Bidders, this Proposal, Specifications, Contract, and any and all addenda) and all other conditions of the Proposal, agrees to sell to the City the below listed items for the performance of this Specification, complete in every respect, in strict accordance with the contract documents at and for unit prices listed below.

ADDENDA RECEIPT: The receipt of addenda to the specifications numbers _____ through _____ are hereby acknowledged. Failure of any bidder to receive any addendum or interpretation of the specifications shall not relieve the bidder from obligations specified in the bid request. All addenda shall become part of the final contract document.

THE REQUIREMENTS FOR FIRE STATION VEHICLE EXHAUST REMOVAL UPGRADE

BIDDING SCHEDULE

Bid Item	Item Description	Quantity	Total Price
1.	Station #1	Lump Sum	\$
2.	Station #2	Lump Sum	\$
3.	Station #3	Lump Sum	\$
4.	Station #4	Lump Sum	\$
5.	Station #5	Lump Sum	\$
6.	Station #6	Lump Sum	\$
7.	Station #7	Lump Sum	\$
8.	Station #8	Lump Sum	\$
9.	Station #9	Lump Sum	\$
10.	Station #10	Lump Sum	\$
11.	Station #12	Lump Sum	\$
12.	Station #13	Lump Sum	\$
13.	Station #14	Lump Sum	\$
14.	Fire Mechanics Shop	Lump Sum	\$
15.	PROJECT TOTAL		\$
(Deduc	ets from Above)		
16.	Station #1 Tailpipe modifications	Lump Sum	\$
17.	Station #2 Tailpipe modifications	Lump Sum	\$
18.	Station #3 Tailpipe modifications	Lump Sum	\$
19.	Station #4 Tailpipe modifications	Lump Sum	\$

Bid Item	Item Description	<u>Quantity</u>	<u>Total Price</u>	
20.	Station #5 Tailpipe modifications	Lump Sum	\$	
21.	Station #6 Tailpipe modifications	Lump Sum	\$	
22.	Station #7 Tailpipe modifications	Lump Sum	\$	
23.	Station #8 Tailpipe modifications	Lump Sum	\$	
24.	Station #9 Tailpipe modifications	Lump Sum	\$	
25.	Station #10 Tailpipe modifications	Lump Sum	\$	
26.	Station #12 Tailpipe modifications	Lump Sum	\$	
27.	Station #13 Tailpipe modifications	Lump Sum	\$	
28.	Station #14 Tailpipe modifications	Lump Sum	\$	
29.	TAILPIPE MODIFICATION TO	DTAL	\$	
BID SECURITY REQUIRED:YES XX NO				

<u>AFFIRMATIVE ACTION PROGRAM</u>: Successful bidder will be required to comply with the provisions of the City's Affirmative Action Policy (Contract Compliance, Sec. 1.16). The Equal Opportunity Officer will determine compliance or non-compliance with the City's policy upon a complete and substantial review of successful bidder's equal opportunity policies, procedures and practices.

The undersigned signatory for the bidder represents and warrants that he has full and complete authority to submit this proposal to the City, and to enter into a contract if this proposal is accepted.


RETURN 2 COMPLETE COPIES OF PROPOSAL AND SUPPORTING MATERIAL. MARK OUTSIDE OF BID ENVELOPE: SEALED BID FOR SPEC. 06-262

COMPANY NAME	BY (Signature)	
STREET ADDRESS or P.O. BOX	(Print Name)	
CITY, STATE ZIP CODE	(Title)	
TELEPHONE No. FAX No.	(Date)	
E-MAIL ADDRESS	ESTIMATED DELIVERY DAYS	

Bids may be inspected in the Purchasing Division during normal business hours after tabulation and review by a Purchasing Agent. Bid tabulations can be viewed on our website at: lincoln.ne.gov Keyword: **Bid** The Intent to Award will be listed on the website when a recommendation is received from the Department.


ELECTRICAL KEYED NOTES:

- 1 ROUTE 2#12 & 1#12GRND IN 3/4"C FOR NEW APPARATUS BAY EXHAUST FAN EF-1 TO NEW 20AMP, 2-POLE BREAKER IN EXISTING PANEL LOCATED IN EXISTING MECHANICAL/ELECTRICAL ROOM, NEW BREAKER WILL BE INSTALLED IN SLOTS #2,4, MATCH EXISTING AIC RATING. MOUNT MOTOR STARTER ON WALL NEAR EXHAUST FAN. SEE CONTROL PANEL AND EXHAUST FAN WIRING DIAGRAM.
- Z ROUTE 2#12 & 1#126RND IN 3/4"C TO
 SPARE 20AMP, 1-POLE BREAKER SLOT #25
 IN EXISTING 200A PANEL LOCATED IN FIRST
 FLOOR MECHANICAL/ELECTRICAL ROOM FOR
 NEW WALL MOUNTED RECEPTACLE SERVING
 NEW 2 HP AIR COMPRESSOR, COORDINATE
 MOUNTING HEIGHT OF RECEPTACLE WITH
 MECHANICAL AND EXISTING CONDITIONS.
- $\sqrt{3}$ NOT USED.
- 4 EXISTING 200AMP, 120/240V, 10 PANEL.
 REMOVE EXISTING 25AMP, 2-POLE BREAKER
 SERVING DEMO'ED APPARATUS BAY
 EXHAUST FAN. SEE NOTE #1 FOR NEW
 BREAKER INSTALLATION.
- 5 ELECTRICAL CONTRACTOR TO METER EXISTING PANEL FOR EXISTING LOAD TO VERIFY CAPACITY FOR ADDED LOAD.





The design and concepts illustrated here are the sole property of M.E. Group, Inc. (MEG), they may not be reproduced in whole or in part without express written permission.



ADDENDUM #3

NOT TO SCALE

N/A

Reference Sheet:

The design and concepts illustrated here are the sole property of M.E. Group, Inc. (MEG), they may not be reproduced in whole or in part without express written permission.

City of Lincoln

Cllent/Architect:

Project No.:

09.18.2006

637.001

MEG File No.:

Lincoln Fire Stations Diesel **Exhaust Systems**

